

Public Works & Utilities Report

September 12, 2023 – October 12, 2023

HR

Dawson

Sick/Medical/PN: -
Holidays: -24
OT Earned: +1
OT Off: -5

Dwayne

Sick/Medical/PN: -8
Holidays: -
OT Earned: -
OT Off: -

Nathan

Sick/Medical/PN: -16
Holidays: -
OT Earned: +1
OT Off: -

Utilities

- Monthly sewer and well checks and data logging on going.
- Daily morning and afternoon rounds and daily data logging on going.
- Ongoing ordering of chemicals and supplies for the water treatment plant.
- Ongoing cleaning and tidying at water treatment plant, wells and SLS.
- Ongoing filing and organizing of documents.
- Continued treatment of lagoon with enzyme.
- Weekly bacteriological samples sent in.
 - o No positives reported. :)
- Call Before You Dig Requests: 12
- Month end water meter readings.
- Continued GPS mapping water valves, manholes, hydrants, hydrant valves, curb-stops, and anything else we can. Worked on drawing water lines, labeling lines, and adding more info for each water line.
- Turned a couple waters off for non-payments and at owner's requests.
- Turned on and sanitized new school water line. Flushed the line and left on. The meter was installed by their plumber and the service is now on for the time being.
- Made trip to Nipawin to get a few parts for chainsaws and purchase Glycol Anit-freeze for hydrant winterization.
- Turned off water and blew out lines for Tourist Booth Bathroom, Ball Diamond Bathrooms and Community Square.
 - o Blew out water sprinklers at community square.
- Ordered diaphragm kits for chlorine pumps. One requires services and the other is for a spare.
- EPO visit for Lagoon inspection:
 - o Lagoon banks need work done to them and should be budgeted for next year. The one cell has a bad erosion spot that will need to be fixed and other banks have erosion on them as well.
- Ries has informed me that he will no longer be our EPO as of November 1 as the Water Security Agency has redrawn the boundary lines for their jurisdictions. We will have a new EPO out of Prince Albert.
- Flushed dead end waterline at 3rd St. Southeast due to falling chlorine levels and lack of water usage at the end of the line.
- Downloaded quarterly lagoon report for R.M. and submitted.

Public Works & Utilities Report

September 12, 2023 – October 12, 2023

- Cut down some water main valves inside tubes preventing the lids from not seating correctly.

Public Works

- Ongoing cleaning inside and out of equipment and trucks.
- September Garden Refuse/Bag Pickup
 - o Lots out this time around. Hauled around 10 truck loads.
- October Garden Refuse/Bag Pickup
 - o Hauled out around 6 truck loads.
- Fall Sweeping is in progress. Trying to get all the leaves that fall from the trees.
 - o Prevents storm drainage blockages during spring run off.
- Started measuring lots in rental area at Bulk Esso lot and marked out specific areas for people to rent. Still got some work to do when time permits.
- Cleaned out and organized our truck storage shed.
- Hauled one load of appliances to Tisdale.
- Started trimming trees around town that overhung roads and sidewalks and hit our equipment.
- Ordered Broom Wafers to replace the wafers on the tractor broom.
- Helped Pat at arena to reconnect the sound system. Checked wires, soldered, and labeled for making future disconnections/reconnections easier.
- Mixed up this year's supply of Salty Sand for intersections and put it into storage shed.
- Picked up new batteries for the 3-ton as the old ones were kaput.
- Piled up trees at tree dump.
- Dug out ends of culverts around town. Still a few more we need to do.
- Started picking up flower pots.