

# Facility Manager's Report

October 10, 2024



## Arena Maintenance:

- Ice Maintenance ongoing – Had lots of roof dripping from building ceiling from condensation.
- Did some ice edging.
- Ice, Lobby, and Sound Room glass was cleaned.
- Bleachers were painted this summer and have been moist due to the building condensation from heat and rain. The dehumidifier is starting to catch up.
- Picked up Kearns Arena sign last week. Removed old sign and the cleaned the wall.
- Put up the new sign this week – had to drill new holes for letter brackets to bolt to other wall brackets.
- Put plexi glass up for one arena glass spot.
- Put up signs for the Thunder.
- Cleaned the players benches.
- Worked on ice gate for room 1-2-3 to help open easier.
- Worked on Zamboni gate to get to even out bottom plate.
- Put new bracket on plant floor base for outside door.
- Helped Mazurek's with ½ ice boards cart, should be done this week.
- Had to replace many ice board screws.
- Painted 4 outside bleachers and replaced board for ball diamonds and Recreation to use.
- Had to come in to work a few warm days and nights to make sure plant was starting up. Set up sprinkler again.
- Geo Electric replaced wire to plant electric motor. It was aluminum wire before and would vibrate wires raw and short out.
- Geo Electric hooked up the new electric stove in the Arena Kitchen.
- Put a tap on a sink in the Zamboni Room.
- Getting a quote on furnace upgrade for one furnace for all of the dressing rooms instead of 2.

## Community Hall:

- Plugged in heaters due to the furnaces being off.

## Mowing:

- Mowed with the Walker one last time.
- Mowed the Town Square one last time.

## Outdoor Arena:

- The puck board has been removed from the ODR. Will take fencing and top rim boards down as we are waiting for line locate to be done again.